



THE STATE  
of **ALASKA**  
GOVERNOR MICHAEL J. DUNLEAVY

## Department of Environmental Conservation

DIVISION OF ENVIRONMENTAL HEALTH  
Drinking Water Program

555 Cordova St. Anchorage,  
Alaska 99501  
Main: 907.262-8201  
Fax: 907.269.7650  
dec.alaska.gov  
[john.davis@alaska.gov](mailto:john.davis@alaska.gov)

November 15, 2024

Sand Point  
Dillon Jacobsen  
PO BOX 249  
Sand Point, AK 99661

RE: Rescinded Boil Water Notice for Sand Point Water System;  
AK2 260294

Dear Sand Point Residents,

A boil water notice (BWN) was issued for Sand Point public water system on Wednesday, October 30, 2024. Drinking water program staff were notified by the operator on Monday, October 28, 2024, that their turbidity samples over the weekend were consistently exceeding 0.3 NTU. Several samples were exceeding 0.5 NTU. In addition, on Tuesday, October 29, the operator reported that entry point residual disinfection readings were not meeting the required 0.2 mg/L.

On November 15, 2024, DEC received three satisfactory total coliform samples, has confirmed with the operator that the turbidity readings are consistently under 0.3 NTU, and that entry point residual disinfection levels are at or above 0.2 mg/L. The water system is back to operating as normal. The BWN has been rescinded.

If you have questions regarding this letter or if I can be of further assistance, please contact me at 907-262-8201 x 201 or at [john.davis@alaska.gov](mailto:john.davis@alaska.gov)

Sincerely,

*John C. Davis*

John Davis  
Environmental Program Specialist  
Drinking Water Program, Anchorage office

Enclosures: Boil Water Notice and Public Notice